



Addendum to Installation Instructions For ML196UHE

Table 16 “Conversion Kit and Pressure Switch Requirements at Varying Altitudes” in Installation Instruction 507966-03 has an incorrect high altitude pressure switch kit part number, for the ML196UHE-070 model. See table 1 and note the correct kit number in bold for the ML196-070. This table supersedes table 16 in the installation instruction.

TABLE 1
Conversion Kit and Pressure Switch Requirements at Varying Altitudes

ML196 Model	Natural to LP/ Propane	High Altitude Natural Burner Orifice Kit	High Altitude LP/Propane Burner Orifice Kit	High Altitude Pressure Switch	
	0 - 7500 ft (0 - 2286m)	7501 - 10,000 ft (2286 - 3038m)	7501 - 10,000 ft (2286 - 3038m)	4501 - 7500 ft (1373 - 2286m)	7501 -10,000 ft (2286 - 3048m)
-030	17H63	14C90	17H66	11U65	11U66
-045	*11K49	73W37	*11K44	11U65	11U66
-070				11U70	11U68
-090				11U70	11U64
-110				11U71	11U64
-135				11U70	11U68

Pressure switch is factory set. No adjustment necessary. All models use the factory-installed pressure switch from 0-4500 feet (0-1370 m).

