

KEY	DESCRIPTION
A188	TRANSDUCER, COMP 1
A190	CONTROL, HEAD PRESSURE
B1	COMPRESSOR 1
B4	MOTOR-OUTDOOR FAN 1
B5	MOTOR-OUTDOOR FAN 2
C1	CAPACITOR-OUTDOOR FAN 1
C2	CAPACITOR-OUTDOOR FAN 2
CB8	CIRCUIT BREAKER-TRANS T1
HR1	HEATER-COMPRESSOR 1
J36	JACK-TEST, COOL
K1,-1,2	CONTACTOR-COMPRESSOR 1
K10,-1,-2	RELAY-OUTDOOR FAN 1
L34	SOLENOID, TWO STAGE
P36	PLUG-TEST, COOL
S4	SWITCH-LIMIT, HI PRESS COMP 1, AUTO RESET
S87	SWITCH-LOW PRESSURE, COMP 1
T1	TRANSFORMER-CONTROL
TB14	TERMINAL STRIP-CLASS II VOLTAGE

——— LINE VOLTAGE FIELD INSTALLED  
 ← DENOTES OPTIONAL COMPONENTS  
 - - - - CLASS II FIELD WIRING


**WARNING - ELECTRIC SHOCK HAZARD CAN CAUSE INJURY OR DEATH. UNIT MUST BE GROUNDED IN ACCORDANCE WITH NATIONAL AND LOCAL CODES.**

FOR USE WITH COPPER CONDUCTORS ONLY.

DISCONNECT ALL POWER BEFORE SERVICING.

IF ANY WIRE IN THIS APPLIANCE IS REPLACED, IT MUST BE REPLACED WITH WIRE OF LIKE SIZE RATING, INSULATION THICKNESS AND TERMINATIONS.

⚠ REFER TO UNIT RATING PLATE FOR MINIMUM CIRCUIT AMPACITY AND MAXIMUM OVERCURRENT PROTECTION.

2022/08		WIRING DIAGRAM	08/22
		538294-01	
DUAL SPEED COMPRESSOR			
ELITE 120-G,J,Y LOW AMBIENT KIT			
SECTION A 2			REV. 0
Supersedes		New Form No. 538294-01	